



P.P.U.H. "Geco" Sp. z o.o.  
30-134 Krakow, ul. Zarzecze 112A  
tel. +48 (12) 6369811, 6361290  
fax. +48 (12) 6362002  
e-mail: [geco@geco.pl](mailto:geco@geco.pl)  
<http://www.geco.pl>

## **SERVICE & OPERATING INSTRUCTIONS FOR AUTONOMOUS CONTROL UNIT**

# **G-207-P00...**

### **VERSION FOR REFRIGERATING SYSTEMS**

*For program version 01*

Please read these instructions very carefully before connecting and starting any of our equipment. In cases of any doubt, please contact our company between 8:00 a.m - 4:00 p.m. Any comments sent by e-mail will be of valuable help to us.

Note!!! At the bottom of the following pages there is the last update date, and at the end of p. XVI you can find information on successive revisions of the program versions and mode of operation

Please always use the latest version of instructions, which you may obtain free of charge by mail upon request.

## GENERAL

**NOTE!!!** Since this manual refers to a number of very similar types of thermostats we will hereinafter refer only to the name of much more advanced thermostat with G202 symbol.

**Autonomous Control Unit hereinafter** referred to as **G-207** is a state-of-the-art, convenient and easy to use system. It's design combines microprocessor-based technology and automatic surface assembly.

Thanks to its two-part housing and innovative engineering solutions G-207 can be used with each type of furniture and simple cooling chamber. The control panel being supplied from **safe voltage (5V)** can be mounted in any place, without being necessary to cut additional holes and run many supply cables far from the controlled equipment.

G-207 is equipped with two temperature sensors, it enables connection of the door sensor to the control panel or the actuator – they operate then being supplied by **safe voltage 5V** and have five outputs enabling direct connection of the equipment supplied with 230V with a load capacity as per table 1.

When used with refrigerating systems the G-207 stabilizes the temperature and controls automatic defrosting mode, the time of which can be adjusted to specific ambient conditions, it also incorporates a button for manual defrosting of the evaporator. Versions with lighting switch working independently from the main switch are available.

These thermostats do not require any special maintenance; the console is made of special foil resistant to high temperatures and most chemical agents. Do not use sharp objects for cleaning it, you only need to wipe the front panel with a damp cloth from time to time.

## METHOD OF MARKING AND TECHNICAL DATA

Model symbol: **G- 2 07 –P 00K X X – M 1XXXX X**  
 Item: **1 2 3 4 5 6 7 8 9 10 11**

- 1- Thermostat "Geco".
- 2- For refrigerating applications.
- 3- Type of enclosure: 07 –minipanel, 5-relay base unit
- 4- Start of coding related to the panel (keypad).
- 5- Program version 00 – universal,.
- 6- Way of setting the temperature: Ê- keypad.
- 7- Presence of the light button: L – light button present, 0 – no button.
- 8- Buzzer: B – buzzer present, 0 – no buzzer .
- 9- Start of coding related to actuator.
- 10- What relays are installed. Detailed description is given below.
- 11- Door sensor: D – mechanical or magnetic door sensor, Y - optical door sensor, 0 – the door sensor cannot be connected.

Additional information on relay coding.

Digits indicate relay presence, 0- no relay:

- 1 – compressor relay - required
- 2 – light relay
- 3 - fan relay
- 4 - heater / valve relay
- 5 - second compressor relay

The simplest thermostats are equipped with:

- 10005 - **compressor**

- **12005 - compressor and light**

And most advanced with:

- **10345 – compressor, fan, heater.**
- **12345 - compressor, light, fan, heater.**

Other examples

- **10305 – compressor and fan**
- **10045 – compressor and heater**
- **12305 – compressor, light, fan**
- **12045 – compressor, light, heater**

Operating voltage	-	230V +10% -15%
Ambient temperature	-	from +5°C to +40°C
Moisture	-	from 20% to 80% RH
Protection degree	-	IP65 from the front side of the control panel

*Table 1: Marking of relays and output load-carrying capacity*

OUTPUT	RELAY	RECOMMENDED MAXIMUM CONTINUOUS LOAD		
P1 – Compressor	30A	8A	2HP	1500W
P2 – Light	16A	4A	-	750W
P3 – Fan	16A	4A	1HP	750W
P4 – Heater	16A	8A	-	1500W
P5 – Compressor	30A	8A	2HP	1500W

### **Note !!!**


- **The currents specified in table are the currents drawn by individual units during normal operation and take into account start-up currents of these units !!!**
- **Total current drawn at the same time by the units must not exceed 10A!!!**

## **METHOD OF ORDERING**

When placing your order please specify the following:

1. Controller type: e.g. G-207-P00-KLB-M12345D
2. Length of the ribbon connecting the actuator and the keypad panel.
3. Length of the temperature sensors.
4. Length of the door sensor cable – if it is to be hooked up to the control panel (keypad)
5. Additionally, you can also order non-contact door sensors:
  - magnetic sensor, with a range of 1-2 cm.
  - optical sensor, with a range of 1-2 cm.

## **DELIVERY, INSTALLATION AND HOOKUP**

1. In the appropriate place in the unit cut a hole of 20x30mm in size, however if masking frame of the panel is not used the size of the hole should be 58x109mm.
2. Mount the actuator on the rail and latch it.  
***For store equipment the SBR actuator MUST be fixed to the floor!!!***
3. Any metal elements, through which the G-207 or its cables are run should be ground or protected otherwise. Fitting G-207 to enable direct action of water on it (e.g. water condensating on the bottom cover of the shop window), touching the outlet pipe from the evaporator etc. and changing considerably its temperature in relation to the ambient temperature (e.g. fitting in the immediate proximity of the compressor and its accessories, cooled and heated elements) is not allowed.
4. Cut the ribbon connecting the panel with the actuator into the desired length plus 2-3cm. Then, after running it through all penetrations, cut it once more by cutting its ends at right-angle and clip the plugs on it so that the end of the ribbon is hidden to approx. 0.5mm. The ribbon must be introduced perpendicular to the plug and clipped so as to make its twisting or non-parallel layout impossible. Connecting the ribbon to the connectors see *figure at the end of the instructions*.
5. After fastening the G-207, connect the power cables according to the description provided on the actuator enclosure. Depending on the G-207 version some outputs may not be used - on the description label they will not be described and the type symbol in the corresponding places will contain zeroes - ***do not connect any conductors to these outputs!!!***
6. Make sure to connect the jumper supplying P5 relay – see label on the actuator enclosure. If the jumper is not connected there will be no power at the P5 output.
7. Any cable surplus should be cut down or winded up and clamped using special plastic bands. The cables must be firmly secured on its entire length and must not get in contact with the compressor and its equipment.
8. ***After connecting the unit to the power source there can be voltage across the lighting cable regardless of switching on or off the unit with the button , therefore the starter or the fluorescent lamp should be replaced only with the power cord disconnected from the plug!!!***

### **THE SAME APPLIES WHEN CARRYING OUT ANY OTHER REPAIRS!!!**






8. If you use heaters, their power must be rated so that in case of G-207 or plug failure and being switched on permanently there will be no risk of fire or damage to the equipment. ***If high power heaters are used it is absolutely necessary to install a safety thermostat on the evaporator, the principle of operation of this thermostat should be different e.g. mechanical.***

## THE PRINCIPLE FOR INSTALLATION OF SENSORS, TYPES OF PROTECTIVE CASES






1. For *each* type of the manufactured equipment a place for securing the chamber and evaporator sensors and SBR settings should be determined *experimentally*. Absolutely do not change the fastening location nor the way the sensors are secured nor modify SBR settings without prior carrying out new tests relating to temperature stabilization and equipment defrosting cycle !!!
2. Fastening of the chamber sensor must be done in such a way so that it does not get in contact with food products and is not exposed to damage when cleaning the equipment. The sensor can be fixed using a special plastic bracket. This solution causes fast (on/off time delays see VI p.7 and 8) response of the sensor and the entire thermostat to the change in the air temperature in the unit. When desired or necessary to slow down and "smooth" the time of sensor response to the temperature changes we recommend to fix it to the metal part of the unit.
3. Fasten the evaporator sensor in the way to ensure maximum and good contact with the evaporator lamella and in place where ice remains for the longest time during defrosting. Its fastening should prevent it from being pushed out by the growing ice. The sensors, wherever possible, should be fixed vertically so that the cable exits from the bottom of the sensor.
4. **Sensor cables** can be shortened or extended in any way, however with respect to the following rules:
  - do not cut the sensor cable at a section smaller than 0.5 m. from the case
  - it is not recommended to extend the sensor cable to more than 20 m.
  - THE SENSOR CABLES CAN BE CONNECTED TO THE TERMINALS OF THE ACTUATOR SENSORS IN ANY WAY!!!  
(in the same way as you connect the plug to the ~230V outlet)
  - for cable extension we recommend using OMY 2x0.5 mm type conductor
  - connect the extended cables with great care, by soldering each pair of cores and put thermally shrinkable jackets on them. Then apply waterproof silicone on the joint and clamp one more thermally shrinkable jacket on it.
  - whiten the ends of the conductors connected to S.B.R. with tin

## MODE OF OPERATION





### A - General

1. After connecting the unit to the power source a 3-second start-up procedure will be performed, during which two dots will appear on the display for 1 second, following by the number of the controller program version for the next second and then two dots again. At this time no controlled unit is switched on.
2. After completing the start-up procedure as per section 1 two horizontal bars will appear in the central panels of the display indicating "energized" state – provided that the unit has not been energized before!!! The unit is started up after pressing the button . A temperature value of the chamber sensor appears on the display.
3. After pressing and holding  for 0,5 sec. the display will start blinking and showing temperature *of the evaporator*, after elapse of subsequent 5 secs G-207 will automatically return to chamber temperature reading. **Note!!!** This function is also active during defrosting, when "dF" is indicated on the display. The temperature from the chamber sensor can be also seen by pressing  for 0,5 sec., the display will start showing (*without blinking*) the chamber temperature, after elapse of subsequent 5 secs G-207 will automatically return to display "dF".
4. Switching on of the compressor is indicated by small red LED (dot) lighting in the right bottom corner of the display indicating the temperature. This makes it easier to check possible system failure.
5. If the compressor is to be started then compressor P5 is switched on and then after 6 seconds compressor P1. The same happens when turning off the units, P5 is turned off first and then P1 after 6 seconds.
6. When the compressor should start, but it will not because of tripping one of the safety devices (see point 7), the dot indicating compressor operation will be blinking. After the time preset from the safety devices elapses the dot will light continuously and the compressor will be started.
7. The delay in starting the compressor **after reaching** its starting temperature (user-preset temperature minus lower hysteresis limit) is 30 secs. If during that time the temperature drops the 30 second limit condition will be checked again. This is to protect the compressor from being unnecessarily turned on such as when inserting the product, draughts, etc.
8. Each time the preset temperature is reached (user-preset temperature plus upper hysteresis limit) and after each power voltage failure or voltage drop below 175V, G-207 will prevent the compressor from being restarted for the time set by parameter 'c2'. However, if 'c2'=0min, after power loss safety mode will last for 60 secs.
9. After starting the unit by pressing  the compressor will be started after 5-second delay. Please note that this cancels the power loss safety mode as per point 7 - this also concerns the time determined by parameter 'c2' after prior shutting down the compressor. This way it is possible to faster check functioning of the compressor.
10. The controller has been equipped with alarms indicating the sensor failure. The controller will behave differently depending which sensor is defective.
  - Failure of the chamber temperature sensor will result in displaying **A1** symbol. The controller will start the compressor in the time cycle (the so called "clock control") according to the times set in parameters 'c8' and 'c9'. Defrosting will work normally.
  - Sensor failure evaporator will display the alarm **A2**. **Manual and automatic defrosting is inhibited!!!** The only possible way of defrosting the unit is to turn it on using button  and wait until ice melts in natural way.

- If simultaneous failure of two sensors occurs the only alarm which is displayed is **A1**. When the chamber sensor is repaired **A2 alarm will go on**.

11. If a buzzer is incorporated into the controller, see *sec. II*, each button pressing is signaled by the controller with buzzer beep. If the controller is turned off (two horizontal bars on the display) the buzzer only indicates pressing  and .
12. The lighting is turned on and off after pressing the button . This is indicated by lighting up of the green LED by the button. If the light goes on in the result of door opening this LED will not light up. Button  works independently from the thermostat power switch - .

## **B - Defrosting**

1. If extra defrosting is necessary due to severe operating conditions then press button . The green LED will light continuously on the button  and "dF" will appear on the display instead of temperature measurement, now the unit will enter the defrosting cycle.
2. If defrosting starts and the evaporator temperature is **higher** than the one preset with parameter 'd2' then the unit after approx. 10 seconds will enter the defrosting phase exit mode and when it is over it will resume operation.
3. If defrosting starts and the evaporator temperature is **lower** than the one preset with 'd2' then G-207 will start defrosting and on reaching the temperature preset with 'd2' it will enter **the defrosting exit procedure** (this state is indicated by *green LED blinking on the button* ) , in version with heaters defrosting exit procedure is started, which comprises two subsequent phases:
  - **dripping phase** – in which compressor and evaporator fans remain turned off for the time set by 'c3'
  - **evaporator freezing out phase** – in which only the compressor is running in order to lower the evaporator temperature down to a temperature set by 'd5' before restarting the fans. Maximum and non-exceeding time of freezing out regardless of reaching the temperature 'd5' by the evaporator is set with 'c4'.
4. Defrosting exit procedure ends along with the start of fans, and "dF" goes off on the display and green LED starts blinking on the button .
5. If the fans are not present or not connected to S.B.R. the system will operate as if they were installed.
6. Defrosting will end *when the evaporator temperature reaches the value preset with 'd2' or when the time preset with 'c1' elapses*.
7. When "dF" goes off and defrosting is over the display will show the temperature memorized just before the start of defrosting for the time preset under 'c7' – this is to avoid possible complaints due to "rapid temperature fluctuations within the unit".
8. The system behaves in the same way as with **manual and automatic defrosting**.

### C – Principle of operation of the door sensor

1. If the door is opened the fan will be immediately stopped and in G-207 depending on the 'r7' settings the light may go on. A temperature is shown on the display.
2. After 30 secs elapses, if the door is closed "dr" symbol will be shown **continuously** on the display. In the controllers equipped with a buzzer a short beep will be heard, repeated every 30 seconds.
3. If the door remains open after the time set by 'r8' elapses the alarm is activated, which is indicated by **the blinking display** showing "dr" and in buzzer version - by beep. At this moment the compressor is turned off.
4. If R8 = 0, immediately on opening the door alarm is activated.
5. Pressing any button will mute the alarm. Closing doors deactivates the alarm and the operation is resumed.
6. The controller allows connecting both mechanical door sensor jumpered when the door is being opened (R6=01), as well as mechanical or magnetic sensor, opened when the door is being opened (R6=02).


### **HYSTERESIS**

When programming the parameters 'd0' and 'd1' (minimum and maximum temperature, which can be preset by the user) please remember that hysteresis value 'd3' additionally 'pulls' the temperature down and up from the user-preset temperature.

This is particularly important in case of "positive" units, which should always operate at a temperature above 0°C.

As the Manufacturer of the refrigerating system, in this case the refrigerated counter (positive temperature) we expect from the unit to **allow** operation within temperature limits not to exceed the following values: Turning off min: 2°C. Turning on max: 10°C

Symmetrical hysteresis for even values 'd3'	Symmetrical hysteresis for odd values 'd3'
<p>Example 1. Now, let's set the hysteresis 'd3' to 2°C For the above mentioned setting of the hysteresis you should set the parameter: 'd0' to 3°C a 'd1' to 9°C</p>	<p>Example 3. Now, let's set the hysteresis 'd3' to 3°C For the above mentioned setting of the hysteresis you should set the parameter: 'd0' to 3°C a 'd1' to 8°C</p>
<p>Example 2. Now, let's set the hysteresis 'd3' to 4°C For the above mentioned setting of the hysteresis you should set the parameter: 'd0' to 4°C and 'd1' to 8°C</p>	<p>Example 4. Now, let's set the hysteresis 'd3' to 5°C For the above mentioned setting of the hysteresis you should set the parameter: 'd0' to 4°C and 'd1' to 7°C</p>





## START DIAGRAMS FOR INDIVIDUAL COMPONENTS OF THE UNIT

The bold line denotes **start**, and broken line **stop** of particular units. Defrosting exit consists of two phases - see Chapter V sec.3.

The field "Standstill" means shutdown, and "Operation" starting the compressor as the result of exceeding the preset temperature, naturally taking into account the value of preset hysteresis 'd3'. The heater on Fig. 1 is designed for heating up the tray and/or the hose draining water from the evaporator. The heater on Diagram 4 is designed **only** for heating up the hose draining water from the evaporator.



### ERRONEOUS SETUP OF THE PARAMETERS WILL RESULT IN UNIT MALFUNCTIONING!!!


1. Defrosting by compressor standstill 'r1'=01, fans are running only with the compressor 'r2'=00



2. Defrosting by heater 'r1'=02, fans are running only with the compressor 'r2'=00




3. Defrosting using hot steam 'r1'=03, fans are running only with the compressor 'r2'=00




4. Defrosting using hot steam 'r1'=03, fans are running all the time after turning on the unit 'r2'=01



5. Defrosting by compressor standstill 'r1'=01, fans are running all the time after turning on the unit 'r2'=01













6. Defrosting by heater 'r1'=02, fans are running all the time after turning on the unit 'r2'=01



## PROGRAMMING THE SYSTEM PARAMETERS

After starting up and checking if the unit is working correctly (factory preset standard settings) G-207 system parameters can now be entered.

For this purpose turn off the unit using the button . **Then press button  and  and while holding them press .** All three buttons must be kept pressed down at the same time for 3 secs. Releasing any of the buttons at this time quits the programming mode. After this operation the LEDs should start **blinking** on buttons  and  and 'c0' symbol will appear on the display for one second. Now the last programmed value for this parameter will appear. Now using  enter required settings, pressing the button for longer time makes fast "scrolling" of the indications. Then press button , to accept the entered value and proceed to enter the next parameter.

It is possible to enter the settings partially, if you do not want to change the particular setting press  and G207 will move to the next parameter.

## **Note !!!**

Access to the part or even all parameters entered from the keyboard can be inhibited by the refrigerating system Manufacturer using the computer programmer.

In this case when attempting to modify the settings of the inhibited parameter 'bL' will appear on the display for approx. 1 sec.

### **Remarks on SBR programming.**









1. ***IT IS THE RESPONSIBILITY OF THE MANUFACTURER OF THE REFRIGERATING UNIT AND THE SERVICE ENGINEER TO ENTER NEW SETTINGS REQUIRED FOR NORMAL FUNCTIONING OF THE UNIT!!!***
2. Do the programming carefully, preferably writing down earlier the values of the particular parameters on a sheet of paper. Remember that any error made when programming some parameters will have very serious consequences including damage of the product and the refrigerating unit.
3. Having programmed and started the unit check it for proper operation and recheck if the settings of the system parameters are correct.
4. Transfer of the Service Instructions or any information regarding the mode of programming the SBR system parameters to the end user is absolutely not allowed. The end user should receive only and exclusively a copy of the section IX of these instructions.

Table 2: Parameter designations


Parameter	Description	Min	Max	Increment	Factory preset
c0	How often should defrosting be started <i>Note!!! If this parameter is set to "0" defrosting <b>will not be</b> started in automatic, but only in manual mode!!! If this parameter is set to "-01" defrosting <b>will not be</b> started neither in automatic, or manual mode!!!</i>	0 -01	24	1h	6h
c1	Maximum defrosting time if the evaporator does not reach the preset temperature (parameter d2) <i>Note!!! If this parameter is set to "-01" there will be no time limitation</i>	10 -01	99	min	min
c2	Minimum standstill of the compressor	0	15	1min	3min
c3	Evaporator dripping time	0	15	1min	2min
c4	Time of freezing out of the evaporator, after which the fans are started whether the evaporator reaches the preset temperature set by 'd5' or not	0	25	1min	10min
c5	Maximum operation time of the compressor 0 – means no test (disabling this parameter)	0	99	1min	40min
c6	Standstill of the compressor after safety system trip set by 'c5'	0	99	1min	10min
c7	The time for which the temperature measured immediately before the start of defrosting will be shown after the end of defrosting (parameter 'c4').	0	60	1min	5min
c8	Time of operation of the compressor with faulty control sensor	1	99	1min	25min
c9	Standstill of the compressor with the faulty control sensor	1	60	1min	5min
d0	Min. temperature to be set by the client	-40	20	1°C	1°C
d1	Max. temperature to be set by the client	d0+1	40	1°C	10°C
d2	Evaporator temperature at which defrosting will be stopped	0	40	1°C	5°C
d3	Hysteresis value	1	10	1°C	2°C
d4	Rescaling value of the chamber sensor in relation to actually measured temperature	-10	10	1°C	0°C
d5	Evaporator temperature, at which fans begin operation after finishing the defrosting process	-30	10	1°C	-5°C

r1	Specifying the evaporator defrosting method, parameter set to: 01 – defrosting by compressor standstill 02 – defrosting by heater 03 – defrosting using hot steam valve (reversed circulation)	01	03	1	02
r2	Specifying the evaporator fan operation mode, parameter set to: 00 – fans running only with the compressor 01 – fans running all the time after turning on the power <b>NOTE!!!</b> This parameter has no effect on the cycle and evaporator defrosting mode	00	01	1	01
r3	Specifying the temperature control mode, parameter set to: 00 – Normal control operation 01 – temperature is controlled according to the measurement from the evaporator sensor, preset temperature and parameters D0, D1, D2 and D3 refer to evaporator sensor, measurement from the chamber sensor is displayed.	00	01	1	00
r5	Defrosting start conditions when starting the unit. 00 – starting the operation without defrosting 01 – if during defrosting power loss is encountered then defrosting will be started 02 – defrosting each time the unit is turned on.	00	02	1	00
r6	Door sensor option. 00 – no door sensor 01 – there is a door sensor jumpered when the door is opened 02 – there is a door sensor opened when the door is opened	00	02	1	01
r7	Mode of turning on the lighting 01 – light control only by the door sensor 02 – light control only by the key 03 – light control by the door sensor and the key	01	03	1	03
r8	Time from door opening to alarm activation. 30 seconds after door opening "dr" symbol is displayed. In the controllers equipped with a buzzer a short beep will be heard, repeated every 30 seconds. Once R8 time has elapsed the alarm is activated, which is signaled by the blinking display showing "dr" symbol and with buzzer version - you will hear a beep and the compressor will be turned off. 0 – means immediate alarm activation	0	20	1min	1min
r9	Area where the door sensor should be hooked up: 01 – sensor hooked up to the module with relays 00 – sensor hooked up to the control module – Note! in this case you should order a special cable with a plug!!!	00	01	1	01

## OPERATION OF G-207 - FOR THE USER

1. After connecting the unit to the power source, two dots will appear on the display for 1 second, following by the number of the controller program version and then dots again for the next second. Then two horizontal bars will appear on the central panels of the display indicating the "power-on" state. The unit is started up after pressing the button . A temperature value of the chamber sensor appears on the display.
2. Setting up the stabilized temperature in the glass case.
  - To change the settings, press the button . The green indicator will light on the button and the value of the last programmed temperature is shown on the display.
  - The temperature is set using the buttons  . Longer pressing of the button will result in fast "scrolling" of the indications.
  - After the desired temperature is set, press again button . After this operation the green indicator on the button will go off and G-207 will quit the programming mode and start new program execution.
  - If button  is not pressed, G-207 will automatically quit the programming mode after about 5 seconds since last use of the button. The temperature value will not be saved in this case.
3. The lighting is turned on and off after pressing the button , the green LED is lit if the lighting is on. The light switch works independent from the main switch .

### **IMPORTANT !!!**

If additional defrosting is necessary, due to severe operating conditions, press the button . The green LED will light up on the button, and "dF" will appear on the display instead of the temperature measurement and the unit will enter the defrosting cycle.

Defrosting will end automatically after the preset time elapses or on reaching the factory preset temperature.

**Attempting to repair the unit, will void the guarantee and may lead to electric shock and burn by hot steam. Therefore all repairs should be performed by the trained and qualified service personnel !!!**

## TROUBLESHOOTING

Failure symptoms	Check
1. The display is off even if G-207 is connected to the power supply	Check: <ul style="list-style-type: none"> <li>- if 220V is present across the power supply terminals L and N</li> <li>- correct connection of the actuator to the control panel</li> <li>- remove and reinsert the ribbon sockets</li> <li>- connect another ribbon</li> </ul>
2. The compressor will not start despite its power-on signaling <ul style="list-style-type: none"> <li>- red LED</li> </ul>	Check: <ul style="list-style-type: none"> <li>- 220V voltage presence on terminals K and N - If present, then check the compressor</li> <li>- if not, then check correct connection of the actuator with the control panel</li> <li>- check the jumper feeding the relay P5</li> <li>- connect another ribbon</li> </ul>
3. Heater defrosting will not start	Check: <ul style="list-style-type: none"> <li>- presence of 220V across the terminals according to the description found on the upper panel of the actuator</li> <li>- if present then check the heater</li> <li>- if not, then check correct connection of the actuator with the control panel</li> <li>- connect another ribbon</li> </ul>
4. Fluorescent lamp will not light up	Check: <ul style="list-style-type: none"> <li>- presence of 230V across the terminals according to the description found on the upper panel of the actuator</li> <li>- if present, then check a/ starter b/ fluorescent lamp c/ gland</li> <li>- if not, then check correct connection of the actuator with the control panel</li> <li>- connect another ribbon</li> </ul>
5. Wrong temperature indications	Check: <ul style="list-style-type: none"> <li>- connections of the sensors to the connectors</li> <li>- value of the parameter 'd4'</li> <li>- correct fastening of the sensor</li> <li>- condition of the sensor cable – the cable can not show <b>any</b> damages</li> <li>- carefully the appearance of the external surface of the sensor case for any signs of mechanical damages.</li> </ul>
6. The desired temperature cannot be set	Check: <ul style="list-style-type: none"> <li>- value of parameters 'd0' and 'd1' (<math>d0 &lt; d1</math>)</li> </ul>
7. Blinking of dots on the display, cannot be turned off	Check: <ul style="list-style-type: none"> <li>- power supply voltage value</li> <li>- condition of the power supply connectors</li> <li>- tightening of the power supply connectors</li> <li>- correct connection of the actuator to the control panel</li> <li>- connect another ribbon</li> </ul>
8. 'Abnormal',	Check: <ul style="list-style-type: none"> <li>- if 230V is present across the power supply terminals L and N</li> </ul>

<p><i>'strange' behavior of the unit.</i></p>	<ul style="list-style-type: none"> <li>- condition of the power supply connectors</li> <li>- grounding of the refrigerating unit</li> <li>- condition of the electrical installation and number of the units connected to one phase</li> <li>- if you have the type of thermostat (label with output description) designed for your unit</li> <li>- if the control panel, actuator or the ribbon plugs have been exposed to water or any other liquid</li> <li>- if the control panel, actuator or ribbon plugs are exposed to moisture or rapid temperature fluctuations</li> <li>- correct connection of the actuator to the control panel</li> <li>- connect another ribbon</li> </ul>
<p><i>9. Problems with defrosting the unit</i></p>	<p>Check:</p> <ul style="list-style-type: none"> <li>- value of the parameter 'd2' and 'c0', 'c1'</li> <li>- value of the parameter 'c1'. This is the maximum unit defrosting time, whether the evaporator has reached the programmed temperature of the end of defrosting, or not (parameter 'd2'). If this time is too short complete defrosting of the unit will not be possible</li> <li>- correct fastening of the sensor to the evaporator lamella. <b>IT MUST BE FIXED SECURELY AND ADHERE CLOSELY TO THE LAMELLA!!!</b></li> <li>- if the evaporator sensor is fixed in place, where the ice remains for the longest time, if not, check the temperature on the sensor at the moment, when the last ice lumps fall off the evaporator. <b>THIS IS THE TEMPERATURE WHICH SHOULD BE ENTERED AS PARAMETER 'd2'</b></li> </ul>
<p><i>10. The unit does not reach the preset temperature and does not 'refrigerate'</i></p>	<p>Check:</p> <ul style="list-style-type: none"> <li>- the temperature programmed by the user</li> <li>- value of the individual parameters, and in particular 'c2', 'c5', 'd0', 'd1'</li> <li>- point 9 - <i>Problems with unit defrosting</i>. If unit defrosting is not complete, the unit will not be able to reach the programmed temperature !!!</li> <li>- the way and place of securing the chamber sensor</li> <li>- if any side panes have been fitted in the rack or sliding panes in the glass case</li> <li>- <b>IF THE UNIT IS LEFT IN THE DRAFT OR IN THE SUN !!!</b></li> <li>- if there are no fans or air conditioning units installed on the ceiling or nearby</li> <li>- if condenser is clean</li> <li>- temperature in the store (each manufacturer specifies max. working temperature of the unit)</li> <li>- gas volume, fans, evaporator heater, hose draining water from the evaporator</li> </ul>
<p><i>11. improper operation of the door sensor</i></p>	<p>Check:</p> <ul style="list-style-type: none"> <li>- value of the parameter 'r6' and 'r7', 'r9'</li> <li>- correct connection of the sensor</li> <li>- if the sensor is connected to the actuator, check correct connection of the actuator to the control panel</li> <li>- connect another ribbon</li> </ul>

## RETURNING THE UNIT FOR REPAIRING





In case of failure and returning SBR for repair, it is ***absolutely*** required to ***completely*** fill in the replacement application form provided at the end of these instructions. We suggest making a Xerox copy of the form rather than cutting it.


**PPUH 'GECO' reserves the right to refuse acceptance of the unit for repair free of charge if the form has not been enclosed or submitted incomplete and seal break attempt has been proved !!!**

P.P.U.H. 'Geco' Sp. z o.o. assumes no liability for any loss or damage resulting from offering by the refrigerating unit manufacturer or his service personnel information to the end user on the procedure of modifying the SBR system data, wrong or unprofessional installation and for any loss resulting from faulty operation of the unit.

# BLOCK DIAGRAM, VIEW OF THE ACTUATOR AND METHOD OF INSTALLATION OF THE RIBBON CONNECTING THE PANEL AND THE ACTUATOR



NA RYSUNKU POKAZANO WIDOK WTYCZEK OD GÓRY ORAZ ICH WZAJEMNE UŁOŻENIE WZGLĘDEM SIEBIE I ZAZNACZONEJ ŻYŁY TASIEMKI, PO PRAWIDŁOWYM WYKONANIU POŁĄCZENIA!!!





## SERVICE STAMP

## S.B.R. REPLACEMENT FORM

FIRST & LAST NAME OF SERVICEMAN

DATE OF REPLACEMENT.....

## REFRIGERATING UNIT DATA

MANUFACTURER.....

TYPE:.....COMPRESSOR TYPE.....

SERIAL NO.:.....

DATE OF MANUFACTURE:.....

## S.B.R. DATA

Faulty: PANEL ☐ MAKE MOD. ☐

SERIAL NO.: .....

TYPE: G

## DETAILED DESCRIPTION OF S.R.B. FAULT

## DESCRIPTION OF REFRIGERATING UNIT FAULT

FAULTY: COMPRESSOR ☐ FAN ☐ HEATERS ☐ LIGHT ☐ NO/EXCESS GAS ☐

ATMOSPHERIC DISCHARGE ☐

VOLTAGE LOSS ☐

VOLTAGE DROPS ☐

FAULTY ELECTRICAL INST. ☐

NO GROUNDING ☐

MAINS  
VOLTAGE

V

SERVICEMAN SIGNATURE: